

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITIONCERTIFICATENo. 262Date: 20/5/25

It is certified that an inspection team headed by _____

Chandan Singh Sub Engineer (Name ofOfficers with designation) from Municipal Council Gotegaon PHED inspected thePandit Narmada Prasad Memorial Public School P.H. No. 42, Khasara No. 259/14,Village Kanjai, Tehsil Gotegaon, Distt. Narsinghpur M.P. (Name & Address of theschool) on 19/5/25 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no. _____ dated

21/05/2025 of 21/05/2025(PHED Lab) certified that the Pandit Narmada Prasad Memorial Public School (Name

of school) has safe drinking water facilities for the students and members of staff of

the institution. School is also maintains the hygienic sanitation condition in the school

building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above valid for a period of Three Years.

Signature with Seal

Name: Satendra ShalmarDesignation: Cmo

जिला जल परीक्षण प्रयोगशाला

प्रमाणित

लो. स्वा. धा. विभाग - Name & Address of the Office/ Department: Nagar Palika.

To

Pandit Narmada Prasad Memorial Public SchoolVillage Kanjai, Tehsil Gotegaon, Distt. Narsinghpur M.P.

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTT. WATER TESTING LABORATORY NARSINGHPUR

Lab. Ref.No./Report No.Date.....	District :- Narsinghpur
TO, <div style="text-align: center;">A.F. P.H.E. Narsinghpur.</div>	Details Information of Water Sample/Water Source Location :- Pandit Hamada Prasad Memorial Public School. Village :- Kanjai
Particular of Sample :- Collected / Not Collected By PHED	Block :- Narsinghpur <input type="radio"/> Gotegoan <input checked="" type="radio"/>
Water Source Type :- T/W <input checked="" type="radio"/> H.P. <input type="radio"/> PWSS T/W <input type="radio"/>	Date Of Collection/receipt 21/05/2025
Analysis/Testing Conduct By :- Dist. LAB ANALYST <input checked="" type="checkbox"/>	Date Of Analysis/Testing 22/05/2025

ANALYSIS

S.N.	characteristics	Unit	As per BIS - 10500:2012 For Drinking Water		Water Sample Result	Remark
PHYSICAL TEST :-			Acceptable	Case For Rejection		
1	Temperature	0°			20.0°	
2	Turbidity	NTU	1.0	5.0	2 NTU	
3	colour	Hazen	5.0	15	10	
4	Taste & Odour		Unobjection able		unobjectionable	
CHEMICAL TEST :-						
5	pH		6.5 to 8.5	<6.5 or 8.5>	7.3	
6	Alkalinity	Mg/l	200	600	345	
7	Chloride (as Cl.)	Mg/l	250	1000	140	safe water
8	Nitrate (as NO ₃)	Mg/l	45	45	15	
9	Total Hardness (as CaCO ₃)	Mg/l	200	600	466	
10	Maganese (as Mn)	Mg/l	0.1	0.3	0.1	
11	Total Dissolved Solids(TDS)	Mg/l	500	2000	122	
12	Iron (as Fe)	Mg/l	0.3	1.0	0.49	
13	Flouride(as F)	Mg/l	1.0	1.5	0.68	
14	Sulphate (as SO ₄)	Mg/l	200	400	14.2	
15	Residual Chlorine	Mg/l	0.2	1.0	0.1	
BACTERIOLOGICAL TEST :-						
16	TTC/Thermo tolerant coliform	MPN/100ml	0.0	0.0	0.0	
17	Feacal Coliform/E.Coli	MPN/100ml	0.0	0.0	0.0	

Note:- 1. Not to be produced at Court of Law.

2. We do not take any responsibility in test result due to wrong collection of sample.

3. The figures indicated under column "Acceptable" in the table given above are the limit up to which the water is generally acceptable to the consumer. Figures in excess of those mentioned under "Acceptable" render the water not acceptable in the absence of alternative and better source but up to the limit under "column" case of rejection above beyond which the supply will have to be rejected.

Caution :- The chemical and physical properties of the water change drastically with respect to time therefore ensure that sample reaches the laboratory within the prescribe time limit of 72 Hrs. for potable water. The minimum quantity of the sample required for such test is 2.00 Liters for Bacteriological test the Max prescribe time limit of 30 Min. in case where it is not possible the sample bottle must be kept in ice. for such testes sterilised bottle must be used and these should be filled up to their 2/3 height

Ashwini
CHEMIST

Distt. Water Testing Laboratory Narsinghpur

Phauma
ASSISTANT ENGINEER

PHED SUB DIVISION Narsinghpur